



**INVITATION FOR BID (IFB) No. IFB-PAG-007-21
Caterpillar C-32 910KW Generator Engine Overhaul**

AMENDMENT No. 1

Date: August 3, 2021

ALL BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS AMENDMENT ON AREA PROVIDED BELOW AND RETURN COPY TO PAG PROCUREMENT OFFICE:

Fax: (671) 472-1439 or Email: Priscilla Rideb at pkrideb@portofguam.com, Mark A. Cabrera macabrera@portofguam.com and pagprocurement@portofguam.com.

NOTICE TO BIDDERS: The IFB documents of the above referenced project are hereby **AMENDED TO INCLUDE** the following as part of IFB documents:

1. Amend to change page 30 of 30 with revised page 30 of 30, 8/3/2021. See attached

***** END OF AMENDMENT No. 1, ALL OTHERS REMAIN THE SAME *****

Issued by:

RORY J. RESPICIO
GENERAL MANAGER

Acknowledgement Receipt

COMPANY NAME: _____

AUTHORIZED SIGNATURE: _____

PRINT NAME: _____

DATE / TIME _____ / _____

BID NO.: IFB-PAG-007-21

BID DESCRIPTION: CATERPILLAR C-32 910KW GENERATOR ENGINE OVERHAUL

Item No.	Description	Qty	Unit	Unit Price	Price Extension
1.	Complete Overhaul of two (2) each Generator Set: Model: Caterpillar C-32 910KW Prime Power	2	SE	\$ _____	\$ _____
	<u>Year and Serial Nos.</u>		<u>Hours of Usage</u>		
	2008 S/N SYC003485		32,161		
	2010 S/N SYC005585		25,766		

NOTES:

A. Complete Overhaul

- All work is to be performed by certified Caterpillar technician(s). Bidder's technician must have training, certification, and access to Caterpillar Electronic Software (ET).
- All Parts to be replaced shall be new and genuine (OEM) by generator set manufacturer Caterpillar. Only New Caterpillar parts Remanufactured parts are acceptable.

New Replacement Parts to include:

Cylinder Head assembly's, Connecting Rods, Pistons, Cylinder Liners, Cylinder Packs, Camshafts, Fuel Pumps, Fuel Injectors, Fuel Lines, Turbochargers, Oil Pumps, Oil Cooler, Transfer Pumps, Thrust Bearings, Main Bearings, Water Pumps, Rod Bearings, Valve Rotators, Crankshaft Seals, All Hoses, Fuel, Oil and Air Filters, Gaskets, Bushings, O-rings, V-Belts, Clamps, Fasteners, Batteries, Fitting and Plugs. Engine Block, Crankshaft, Ports, Journals Cleaned and inspected to be within Manufacturers Acceptable Specifications.

- Overhaul of both Generator Sets to include the replacement of Generator End Bearing (Coupling, Element and Washers). Generator to be cleaned and inspected for damage.
- One (1) Year Warranty on Parts **and Six (6) Months Warranty on Workmanship**. Warranty shall begin upon installation of generator to Gantry.
- Post-Overhaul Full Load Tests 100% and shall be performed for 60 minutes, and must pass. Fuel and Load Banks to conduct the tests shall be supplied by the awarded Bidder.
- Generator Overhaul Services to be done offsite. (Port to deliver to Vendor Location and pick up upon Completion).
- All services cost relative to overhaul such as Parts, materials, Labor, Inbound/Ocean Freight, etc., must be included in total price.
- Complete Overhaul for each Generator Set is to be accomplished in ninety (90) days.

These specifications were developed by the staff of Port Authority of Guam, Maintenance Department.
Evelyn G. Pangelinan, Maintenance Planner
Julio D. Yap, Jr., Crane Maintenance Supervisor
Jorge Javelosa, Equipment Maintenance Superintendent
Joaquin P. Pangelinan, Manager-Equipment Support Services
Ernest G. Candoleta, Maintenance Manager